

Licence Number: 11768

Licence Holder: Envirogen PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: October, November and December 2018

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Point 1 - Discharge to Air, Exhaust stack from gas engine 1	10/12/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3	Point 1-4 tested in odd year Point 5, 10 and 11 tested in even year	<450 Dry 273K 101.3kPa 7% O2 1 hour average	420	No
Point 2 - Discharge to Air, Exhaust stack from gas engine 2	10/12/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	380	No
Point 3 - Discharge to Air, Exhaust stack from gas engine 3	15/11/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	300	No
Point 4 - Discharge to Air, Exhaust stack from gas engine 4	15/11/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	300	No
Point 5 - Discharge to Air, Exhaust stack from gas engine 5	10/12/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	340	No
Point 10 - Discharge to Air, Exhaust stack from gas engine 6	15/11/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	440	No
Point 11 - Discharge to Air, Exhaust stack from gas engine 7	15/10/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	410	No