Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: Envirogen PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2018/19

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value	Exceedance (Yes/No)
Jul-18	Point 08 - Effluent quality monitoring - outlet of oil water separator	2/07/18	23/07/18	27/07/18	O&G	mg/L	Monthly	<10	1		<3		No
Aug-18		1/08/18	29/08/18	3/09/18	O&G	mg/L	Monthly	<10	1		<3		No
Sep-18		3/09/18	21/09/18	10/10/18	O&G	mg/L	Monthly	<10	1		<3		No
Oct-18		2/10/18	23/10/18	26/10/18	O&G	mg/L	Monthly	<10	1		<3		No
Nov-18		6/11/18	28/11/18	14/12/18	O&G	mg/L	Monthly	<10	1		<3		No
Dec-18		3/12/18	17/12/18	21/12/18	O&G	mg/L	Monthly	<10	1		<3		No
Jan-19		3/01/19	1/02/19	15/02/19	O&G	mg/L	Monthly	<10	1		<3		No
Feb-19		6/02/19	27/02/19	6/03/19	O&G	mg/L	Monthly	<10	1		<3		No
Mar-19		12/03/19	28/03/19	5/04/19	O&G	mg/L	Monthly	<10	1		<3		No
Apr-19		15/04/19	24/04/19	7/05/19	O&G	mg/L	Monthly	<10	1		<3		No
May-19		3/05/19	27/05/19	29/05/19	O&G	mg/L	Monthly	<10	1		<3		No
Jun-19													