

Lucas Heights 1
 Licence Number: 4805
 Licence Holder: EDL LFG (NSW) PTY LTD
 Licensee Address: Lucas Heights 1
 Testing year: 2019
 Testing Required: Generator Module 5 and Landfill Gas Supply Line



Location of Monitoring Point	Sampled	Obtained	Published	Pollutant	Units of Measure	No. Samples Required by Licence	No. Samples collected and Analysed	Value	Licence Limit	Exceedance (Yes/No)
Discharge and Monitoring Point 5, Generator Module 5	21/03/19	10/06/19	14/06/19	Volumetric flowrate	m3/s	1	1	1.3		
				Temperature	°C	1	1	471		
				Velocity	m/s	1	1	23		
				Sulfuric acid mist and sulphur trioxide (as SO3)	mg/m3	1	1	0.72	100	No
				Sulphur dioxide	mg/m3	1	1	<6		
				Nitrogen Oxides (as NO2)		1	1	450	450	No
				Dry gas density	kg/m3	1	1	1.32		
				Molecular weight of stack gases	g/g-mole	1	1	29.7		
				Carbon dioxide	%	1	1	6.4		
				Moisture Content	%	1	1	3.9		
Carbon monoxide	mg/m3	1	1	510						
Discharge and Monitoring Point 6, LFG Supply Line - DN100 LFG Supply	21/03/19	10/06/19	14/06/19	Volatile organic compounds	mg/m3	1	1	590		
				Dry gas density	kg/m3	1	1	1.55		
				Molecular weight in supply line		1	1	34.7		
				Carbon dioxide	%	1	1	40.4		
				Oxygen	%	1	1	1.6		
				Moisture Content	%	1	1	1.9		
				Temperature	°C	1	1	58		
				Velocity	m/s	1	1	102		
Volumetric flowrate	m3/s	1	1	0.274						