

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: FY 2014/15

Month	Location	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value
Jul-14	Point 08 - Effluent quality monitoring - outlet of oil water separator	29/07/14	13/08/14	27/08/14	O&G	mg/L	Monthly	<10	1		<3	
Aug-14		20/08/14	12/09/14	18/09/14	O&G	mg/L	Monthly	<10	1		<3	
Sep-14		19/09/14	9/10/14	9/10/14	O&G	mg/L	Monthly	<10	1		<3	
Oct-14		29/10/14	17/11/14	20/11/14	O&G	mg/L	Monthly	<10	1		<3	
Nov-14		24/11/14	16/12/14	16/12/14	O&G	mg/L	Monthly	<10	1		<3	
Dec-14		19/12/14	16/01/15	16/01/15	O&G	mg/L	Monthly	<10	1		<3	
Jan-15		2/02/15	18/02/15	5/03/15	O&G	mg/L	Monthly	<10	1		<3	Testing delayed due to operational constraints. Completed early Feb 15 to cover Jan
Feb-15		6/03/15	20/03/15	31/03/15	O&G	mg/L	Monthly	<10	1		<3	Testing delayed due to operational constraints. Completed early Mar 15 to cover Feb
Mar-15		13/03/15	8/04/15	13/04/15	O&G	mg/L	Monthly	<10	1		<3	
Apr-15		30/04/15	22/05/15	25/05/15	O&G	mg/L	Monthly	<10	1		<3	
May-15		30/05/15	8/07/15	15/07/15	O&G	mg/L	Monthly	<10	1		<3	
Jun-15		22/06/15	8/07/15	15/07/15	O&G	mg/L	Monthly	<10	1		<3	