

**Tahmoor Power Generation Plant**

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licence Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2015/16

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value	Exceedance (Yes/No)	
Jul-15	Point 08 - Effluent quality monitoring - outlet of oil water separator	21/07/15	5/08/15	6/08/15	O & G	mg/L	Monthly	<10	1	<3		No		
Aug-15		27/08/15	9/09/15	14/09/15	O & G	mg/L	Monthly	<10	1	<3		No		
Sep-15		12/10/15	7/12/15	7/12/15	O&G	mg/L	Monthly	<10	1	<3		No	Water sampling completed late	
Oct-15		27/10/15	7/12/15	7/12/15	O&G	mg/L	Monthly	<10	1	<3		No		
Nov-15		2/12/15	17/02/16	23/02/16	O&G	mg/L	Monthly	<10	1	<3		No	Water sampling completed late	
Dec-15		3/02/16	17/02/16	23/02/16	O&G	mg/L	Monthly	<10	1	<3		No	Water sampling completed late	
Jan-16		9/03/16	27/04/16	28/04/16	O&G	mg/L	Monthly	<10	1	<3		No	Water sampling completed late	
Feb-16		31/03/16	27/04/16	28/04/16	O&G	mg/L	Monthly	<10	1	<3		No	Water sampling completed late	
Mar-16		17/06/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	Water sampling completed late	
Apr-16		27/06/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	Water sampling completed late	
May-16		1/08/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	Contractor lost original sample taken in May	
Jun-16		6/08/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3		No	Contractor lost original sample taken in June	