

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2016/17

| Month | Location of monitoring point | Sampled | Obtained | Published | Pollutant | Units of measure | Monitoring frequency required by licence | Licence Limit | No. of times measured during month | Min. value | Mean value | Max. Value | Exceedance (Yes/No) | |
|--------|--|------------|------------|------------|-----------|------------------|--|---------------|------------------------------------|------------|------------|------------|---|--|
| Jul-16 | Point 08 - Effluent quality monitoring - outlet of oil water separator | 16/08/2016 | 23/09/2016 | 26/09/2016 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | Contractor lost original sample taken in July | |
| Aug-16 | | 29/08/2016 | 19/10/2016 | 2/11/2016 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Sep-16 | | 19/09/2016 | 19/10/2016 | 2/11/2016 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Oct-16 | | 6/10/2016 | | | O&G | mg/L | Monthly | <10 | 1 | | | | Contractor lost sample | |
| Nov-16 | | 17/11/2016 | 12/01/2017 | 3/02/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Dec-16 | | 16/12/2016 | 12/01/2017 | 3/02/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Jan-17 | | 24/01/2017 | 6/02/2017 | 13/02/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Feb-17 | | 3/02/2017 | 17/03/2017 | 20/03/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Mar-17 | | 20/03/2017 | 10/04/2017 | 11/04/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Apr-17 | | 4/04/2017 | 26/04/2017 | 3/05/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| May-17 | | 1/05/2017 | 19/05/2017 | 19/05/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |
| Jun-17 | | 1/06/2017 | 21/06/2017 | 6/07/2017 | O&G | mg/L | Monthly | <10 | 1 | <3 | | No | | |