Eastern Creek Power Station

Licence Number: 10042 Licence Holder: EDL LFG (NSW) PTY LTD

Licensee Address: Eastern Creek Waste Management Centre, Wallgrove Road, Eastern Creek NSW 2766

Testing year: 2018

	0.1.1.1.1.1.1.1			every 5 years. The Gas Sup		,,,			No. Samples collected		Exceedance
ocation of Monitoring Point	Date Sampled	Date Obtained	Date Published	Frequency	Pollutant	Units of Measure	Licence Limit	by Licence	and Analysed	Value	(Yes/No)
	28/03/18	18/06/18	27/06/18		Carbon dioxide	%		1	1	11.7	
	28/03/18	18/06/18	27/06/18		Carbon monoxide	mg/Nm3		1	1	649.777	
	28/03/18	18/06/18	27/06/18		Dry gas density	mg/Nm3		1	1	1346822	
	28/03/18	18/06/18	27/06/18		Moisture Content	%		1	1	7.4	
					Molecular weight of					30.2	
Discharge and Monitoring	28/03/18	18/06/18	27/06/18	-	stack gases	g/g-mol	<450	1	1		Nie
oint 3, Unit 3 - Air emissions	28/03/18	18/06/18	27/06/18	Point 1-4 and 6 must be	Nitrogen oxides	mg/Nm3 %	<450	1		346.043 7.5	No
nonitoring. Discharge to air,	28/03/18	18/06/18	27/06/18	sampled every 5 years	Oxygen (O2)	%		1	1	7.5	
Gas engine exhaust stack labelled GM3 on drawing					Sulfuric acid mist and						
number 902-BA-002 Rev 0.	28/03/18	18/06/18	27/06/18		sulfur trioxide (as SO3)	mg/Nm3	<100	1	1	63.174	No
	28/03/18	18/06/18	27/06/18	-	Sulphur dioxide	mg/Nm3		1	1	1.226	
	28/03/18	18/06/18	27/06/18		Temperature	°C		1	1	430	
	28/03/18	18/06/18	27/06/18		Velocity	m/s		1	1	39.4	
	28/03/18	18/06/18	27/06/18		Volumetric flowrate	Nm3/s		1	1	1.01	
	28/03/18	18/06/18	27/06/18		Destruction Efficiency	%	>98%	0	1	99.6	
	28/03/18	18/06/18	27/06/18	-	Carbon dioxide	%		1	1	12.8	
	28/03/18	18/06/18	27/06/18		Carbon monoxide	mg/Nm3		1	1	362.476	
	28/03/18	18/06/18	27/06/18		Dry gas density	mg/Nm3		1	1	1352886	
	28/03/18	18/06/18	27/06/18		Moisture Content	%		1	1	7.71	
	20/02/40	40/05/40	27/06/40		Molecular weight of					20.2	
Discharge and Monitoring	28/03/18	18/06/18	27/06/18	-	stack gases	g/g-mol		1	1	30.3	N -
oint 4, Unit 4 - Air emissions	28/03/18	18/06/18	27/06/18	Point 1-4 and 6 must be	Nitrogen oxides	mg/Nm3 %	<450	1	1	348.413	No
nonitoring. Discharge to air.	28/03/18	18/06/18	27/06/18	sampled every 5 years	Oxygen (O2)	70		1	1	6.23	
Gas engine exhaust stack labelled GM4 on drawing	28/03/18	18/06/18	27/06/18		Sulfuric acid mist and sulfur trioxide (as SO3)	mg/Nm3	<100	1	1	43.89	No
number 902-8A-002 Rev 0	28/03/18	18/06/18	27/06/18	1	Sulphur dioxide	mg/Nm3	100	1	1	1.227	
	28/03/18	18/06/18	27/06/18	-	Temperature	°C		1	1	445	
	28/03/18	18/06/18	27/06/18	-	Velocity	m/s		1	1	32.5	
	28/03/18	18/06/18	27/06/18	1	Volumetric flowrate	Nm3/s		1	1	0.81	
	28/03/18	18/06/18	27/06/18		Destruction Efficiency	%	>98%	0	1	99.8	
	28/03/18	18/06/18	27/06/18		Carbon dioxide	%		1	1	28.6	
	28/03/18	18/06/18	27/06/18	1	Dry gas density	mg/Nm3		1	1	1047622	
	28/03/18	18/06/18	27/06/18	1	Moisture Content	%		1	1	16	
Discharge and Monitoring				1	Molecular weight of						
oint 5, LFG Supply Line - Air	28/03/18	18/06/18	27/06/18	4	stack gases	g/g-mol		1	1	23.5	
nonitoring in gas supply line,	28/03/18	18/06/18	27/06/18	Point 5 must be	Oxygen (O2)	%		1	1	3	
Landfill gas supply line belled supply gas on drawing	28/03/18	18/06/18	27/06/18	sampled on any year whenever points 1-4 are	Temperature	°C		1	1	50	
number 902-BA-001 Rev 2	28/03/18	18/06/18	27/06/18	sampled	Velocity	m/s		1	1	3.16	
					Volatile organic compounds (as n-						
	28/03/18	18/06/18	27/06/18	4	propane)	mg/Nm3		1	1	0.014	
	28/03/18	18/06/18	27/06/18		Volumetric flowrate	Nm3/s		1	1	0.111	

Change Log

Date Change 23/07/2020 Amended Frequency column for current year's samples to match the licence requirement

23/07/2020 Inserted Testing Frequency for all monitoring points 23/07/2020 Corrected Sulfur trioxide from 'sulfur trioide' 23/07/2020 Corrected number of samples required for destruction efficiency for Points 3 and 4

23/07/2020 Removed Volatile organic compounds for Points 3 and 4 as no sample was required or analysed