

**Jacks Gully Power Station**

**Licence Number:** 10021

**Licence Holder:** EDL LFG (NSW) PTY LTD

**Licensee Address:** Jacks Gully Waste Managemetn Centre, Richardson Road, Mount Annan NSW 2567

**Testing Year:** 2014 12

**Testing Required:** Jacks Gully Flare

Location of Monitoring Point	Sampled	Obtained	Published	Frequency	Pollutant	Units of Measure	Licence Limit	No. Samples Required by Licence	No. Samples you collected and Analysed	Min. Value	Mean Value	Max. Value
Discharge and Monitoring Point 3. Landfill gas flare	16/12/2014	19/01/2015	3/02/2015	Once every 5 years	Temperature	Degrees Celsius	>760	1	1		787	
	16/12/2014	19/01/2015	3/02/2015		Volumetric flowrate	Cubic metres per second	>0.6	1	1		0.61	

Change Log

Date	Change
21/07/2020	Updated to include Testing Frequency information