



Lucas Heights 2
 Licence Number: 6345
 Licence Holder: EDL LFG (NSW) PTY LTD
 Licensee Address: Lucas Heights 2
 Testing Year 2020

Testing Required Engines 1, 4, 9, 10 and LFG Supply Line

Testing Frequency Engines (1-20) and the Flare are required to be tested once every 5 years. The Gas Supply Line is required to be tested whenever engines are also tested.

| Location of Monitoring Point | Sampled | Obtained | Published | Pollutant | Units of Measure | No. Samples Required by Licence | No. Samples collected and Analysed | Value | Licence Limit | Excedance (Yes/No) |
|--|----------|----------|---------------------|---|-------------------|---------------------------------|------------------------------------|---------|---------------|--------------------|
| Discharge and Monitoring Point 1, Discharge to air, Gas engine exhaust stack labelled 'G101' on drawing number 840-BA-048, Rev A | 30/04/20 | 7/05/20 | 7/05/20 | Temperature | °C | 1 | 1 | 499 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Velocity | m/s | 1 | 1 | 45 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Volumetric flowrate | m ³ /s | 1 | 1 | 1.2 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulfuric acid mist and sulphur trioxide (as SO ₃) | mg/m ³ | 1 | 1 | 0.87 | 100 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulphur dioxide | mg/m ³ | 1 | 1 | <5 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Nitrogen oxides | mg/m ³ | 1 | 1 | 300 | 450 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Moisture content | % | 1 | 1 | 9.3 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Molecular weight of stack gases | g/g mole | 1 | 1 | 30.3 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Dry gas density | kg/m ³ | 1 | 1 | 1.35 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Carbon dioxide | % | 1 | 1 | 11.4 | | |
| Discharge and Monitoring Point 4, Discharge to air, Gas engine exhaust stack labelled 'G104' on drawing number 840-BA-048, Rev A | 30/04/20 | 7/05/20 | 7/05/20 | Temperature | °C | 1 | 1 | 517 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Velocity | m/s | 1 | 1 | 45 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Volumetric flowrate | m ³ /s | 1 | 1 | 1.2 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulfuric acid mist and sulphur trioxide (as SO ₃) | mg/m ³ | 1 | 1 | 1 | 100 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulphur dioxide | mg/m ³ | 1 | 1 | <5 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Nitrogen oxides | mg/m ³ | 1 | 1 | 360 | 450 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Moisture content | % | 1 | 1 | 8.9 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Molecular weight of stack gases | g/g mole | 1 | 1 | 30.3 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Dry gas density | kg/m ³ | 1 | 1 | 1.35 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Carbon dioxide | % | 1 | 1 | 11.4 | | |
| Discharge and Monitoring Point 9, Discharge to air, Gas engine exhaust stack labelled 'G109' on drawing number 840-BA-048, Rev A | 30/04/20 | 7/05/20 | 7/05/20 | Temperature | °C | 1 | 1 | 483 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Velocity | m/s | 1 | 1 | 37 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Volumetric flowrate | m ³ /s | 1 | 1 | 1 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulfuric acid mist and sulphur trioxide (as SO ₃) | mg/m ³ | 1 | 1 | 2.4 | 100 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulphur dioxide | mg/m ³ | 1 | 1 | <5 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Nitrogen oxides | mg/m ³ | 1 | 1 | 360 | 450 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Moisture content | % | 1 | 1 | 9.1 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Molecular weight of stack gases | g/g mole | 1 | 1 | 30.3 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Dry gas density | kg/m ³ | 1 | 1 | 1.35 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Carbon dioxide | % | 1 | 1 | 11.4 | | |
| Discharge and Monitoring Point 10, Discharge to air, Gas engine exhaust stack labelled 'G110' on drawing number 840-BA-048, Rev A | 30/04/20 | 7/05/20 | 7/05/20 | Temperature | °C | 1 | 1 | 490 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Velocity | m/s | 1 | 1 | 34 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Volumetric flowrate | m ³ /s | 1 | 1 | 0.93 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulfuric acid mist and sulphur trioxide (as SO ₃) | mg/m ³ | 1 | 1 | 1.9 | 100 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Sulphur dioxide | mg/m ³ | 1 | 1 | <5 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Nitrogen oxides | mg/m ³ | 1 | 1 | 360 | 450 | No |
| | 30/04/20 | 7/05/20 | 7/05/20 | Moisture content | % | 1 | 1 | 11 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Molecular weight of stack gases | g/g mole | 1 | 1 | 30.3 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Dry gas density | kg/m ³ | 1 | 1 | 1.35 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Carbon dioxide | % | 1 | 1 | 12 | | |
| Discharge and Monitoring Point 21, Gas Supply Monitoring, LFG Supply Line to gas engines labelled 'LFG SUPPLY LINE' on drawing 840-BA-048, Rev A | 30/04/20 | 7/05/20 | 7/05/20 | Volatile organic compounds | mg/m ³ | 1 | 1 | 450 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Oxygen | % | 1 | 1 | 1.3 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Molecular weight of the gases in supply line | g/g mole | 1 | 1 | 34.5 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Carbon dioxide | % | 1 | 1 | 39.5 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Dry gas density | kg/m ³ | 1 | 1 | 1540000 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Moisture content | % | 1 | 1 | 1.6 | | |
| | 30/04/20 | 7/05/20 | 7/05/20 | Temperature | °C | 1 | 1 | 51 | | |
| 30/04/20 | 7/05/20 | 7/05/20 | Velocity | m/s | 1 | 1 | 130 | | | |
| 30/04/20 | 7/05/20 | 7/05/20 | Volumetric flowrate | m ³ /s | 1 | 1 | 0.0097 | | | |

Change Log

Date Change
 23/07/2020 Included frequency of sampling into the data sheet