Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: October, November and December 2018

Testing Frequency: Annual for selected engines

					Units of	Monitoring frequency required			Exceedance
Location of monitoring point	Sampled	Obtained	Published	Pollutant	measure	by licence	Licence Limit	Value	(Yes/No)
Point 1 - Discharge to Air, Exhaust							<450 Dry 273K 101.3kPa 7% O2 1		
stack from gas engine 1	10/12/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		hour average	420	No
Point 2 - Discharge to Air, Exhaust							<450 Dry 273K 101.3kPa 7% O2 1		
stack from gas engine 2	10/12/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		hour average	380	No
Point 3 - Discharge to Air, Exhaust						Point 1-4 tested in	<450 Dry 273K 101.3kPa 7% O2 1		
stack from gas engine 3	15/11/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3	odd year	hour average	300	No
Point 4 - Discharge to Air, Exhaust						oud year	<450 Dry 273K 101.3kPa 7% O2 1		
stack from gas engine 4	15/11/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3	Daint F 10 and 11	hour average	300	No
Point 5 - Discharge to Air, Exhaust						Point 5, 10 and 11	<450 Dry 273K 101.3kPa 7% O2 1		
stack from gas engine 5	10/12/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3	tested in even year	hour average	340	No
Point 10 - Discharge to Air, Exhaust							<450 Dry 273K 101.3kPa 7% O2 1		
stack from gas engine 6	15/11/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		hour average	440	No
Point 11 - Discharge to Air, Exhaust							<450 Dry 273K 101.3kPa 7% O2 1		
stack from gas engine 7	15/10/18	19/12/18	21/12/18	Nitrogen Oxides	mg/Nm3		hour average	410	No

<u>Change log</u> Date Change

20/07/2020 Updated to include the testing frequency.