



**Tahmoor Power Generation Plant**

**Licence Number:** 11768  
**Licence Holder:** EDL (TT) PTY LTD  
**Licensee Address:** Remembrance Driveway TAHMOOR NSW 2573  
**Testing Month/Year:** 2019/20  
**Testing Frequency:** Annual for selected engines

Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Point 1 - Discharge to Air, Exhaust stack from gas engine 1	9/10/19	19/11/19	19/11/19	Nitrogen Oxides	mg/Nm3	Point 1-4 tested in odd year  Point 5, 10 and 11 tested in even year	<450 Dry 273K 101.3kPa 7% O2 1 hour average	420	No
Point 2 - Discharge to Air, Exhaust stack from gas engine 2	9/10/19	19/11/19	19/11/19	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	350	No
Point 3 - Discharge to Air, Exhaust stack from gas engine 3	9/10/19	19/11/19	19/11/19	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	390	No
Point 4 - Discharge to Air, Exhaust stack from gas engine 4	9/10/19	19/11/19	19/11/19	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	400	No
Point 5 - Discharge to Air, Exhaust stack from gas engine 5	NA	NA	NA	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	NA	No
Point 10 - Discharge to Air, Exhaust stack from gas engine 6	NA	NA	NA	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	NA	No
Point 11 - Discharge to Air, Exhaust stack from gas engine 7	NA	NA	NA	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	NA	No

Change log	Date	Change
	20/07/2020	Updated to include the testing frequency.