

**Tahmoor Power Generation Plant**

**Licence Number:** 11768

**Licence Holder:** EDL (TT) PTY LTD

**Licencee Address:** Remembrance Driveway TAHMOOR NSW 2573

**Testing Month/Year:** 2014/15

**Testing Required:** Level of oil and grease in oil water separator

Month	Location	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value
Jul-14	Point 08 - Effluent quality monitoring - outlet of oil water separator	29/07/14	13/08/14	27/08/14	O&G	mg/L	Monthly	<10	1		<3	
Aug-14		20/08/14	12/09/14	18/09/14	O&G	mg/L	Monthly	<10	1		<3	
Sep-14		19/09/14	9/10/14	9/10/14	O&G	mg/L	Monthly	<10	1		<3	
Oct-14		29/10/14	17/11/14	20/11/14	O&G	mg/L	Monthly	<10	1		<3	
Nov-14		24/11/14	16/12/14	16/12/14	O&G	mg/L	Monthly	<10	1		<3	
Dec-14		19/12/14	16/01/15	16/01/15	O&G	mg/L	Monthly	<10	1		<3	
Jan-15		2/02/15	18/02/15	5/03/15	O&G	mg/L	Monthly	<10	1		<3	
Feb-15		6/03/15	20/03/15	31/03/15	O&G	mg/L	Monthly	<10	1		<3	
Mar-15		13/03/15	8/04/15	13/04/15	O&G	mg/L	Monthly	<10	1		<3	
Apr-15		30/04/15	22/05/15	25/05/15	O&G	mg/L	Monthly	<10	1		<3	
May-15		30/05/15	8/07/15	15/07/15	O&G	mg/L	Monthly	<10	1		<3	
Jun-15		22/06/15	8/07/15	15/07/15	O&G	mg/L	Monthly	<10	1		<3	

Testing delayed due to operational constraints. Completed early Feb 15 to cover Jan
Testing delayed due to operational constraints. Completed early Mar 15 to cover Feb

Change log	Date	Change
	20/07/2020	Updated to include the testing required.