

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2015/16

Testing Required: Level of oil and grease in oil water separator

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value	Exceedance (Yes/No)	
Jul-15	Point 08 - Effluent quality monitoring - outlet of oil water separator	21/07/15	5/08/15	6/08/15	O & G	mg/L	Monthly	<10	1	<3			No	
Aug-15		27/08/15	9/09/15	14/09/15	O & G	mg/L	Monthly	<10	1	<3			No	
Sep-15		12/10/15	7/12/15	7/12/15	O&G	mg/L	Monthly	<10	1	<3			No	Water sampling completed late
Oct-15		27/10/15	7/12/15	7/12/15	O&G	mg/L	Monthly	<10	1	<3			No	
Nov-15		2/12/15	17/02/16	23/02/16	O&G	mg/L	Monthly	<10	1	<3			No	Water sampling completed late
Dec-15		3/02/16	17/02/16	23/02/16	O&G	mg/L	Monthly	<10	1	<3			No	Water sampling completed late
Jan-16		9/03/16	27/04/16	28/04/16	O&G	mg/L	Monthly	<10	1	<3			No	Water sampling completed late
Feb-16		31/03/16	27/04/16	28/04/16	O&G	mg/L	Monthly	<10	1	<3			No	Water sampling completed late
Mar-16		17/06/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3			No	Water sampling completed late
Apr-16		27/06/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3			No	Water sampling completed late
May-16		1/08/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3			No	Contractor lost original sample taken in May
Jun-16		6/08/16	23/09/16	26/09/16	O&G	mg/L	Monthly	<10	1	<3			No	Contractor lost original sample taken in June

Change log	Date	Change
	20/07/2020	Updated to include the testing required.