

**Tahmoor Power Generation Plant**

**Licence Number:** 11768

**Licence Holder:** EDL (TT) PTY LTD

**Licencee Address:** Remembrance Driveway TAHMOOR NSW 2573

**Testing Month/Year:** 2016/17

**Testing Required:** Level of oil and grease in oil water separator

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value	Exceedance (Yes/No)	
Jul-16	Point 08 - Effluent quality monitoring - outlet of oil water separator	16/08/2016	23/09/2016	26/09/2016	O&G	mg/L	Monthly	<10	1	<3		No	Contractor lost original sample taken in July	
Aug-16		29/08/2016	19/10/2016	2/11/2016	O&G	mg/L	Monthly	<10	1	<3		No		
Sep-16		19/09/2016	19/10/2016	2/11/2016	O&G	mg/L	Monthly	<10	1	<3		No		
Oct-16		6/10/2016			O&G	mg/L	Monthly	<10	1				Contractor lost sample	
Nov-16		17/11/2016	12/01/2017	3/02/2017	O&G	mg/L	Monthly	<10	1	<3		No		
Dec-16		16/12/2016	12/01/2017	3/02/2017	O&G	mg/L	Monthly	<10	1	<3		No		
Jan-17		24/01/2017	6/02/2017	13/02/2017	O&G	mg/L	Monthly	<10	1	<3		No		
Feb-17		3/02/2017	17/03/2017	20/03/2017	O&G	mg/L	Monthly	<10	1	<3		No		
Mar-17		20/03/2017	10/04/2017	11/04/2017	O&G	mg/L	Monthly	<10	1	<3		No		
Apr-17		4/04/2017	26/04/2017	3/05/2017	O&G	mg/L	Monthly	<10	1	<3		No		
May-17		1/05/2017	19/05/2017	19/05/2017	O&G	mg/L	Monthly	<10	1	<3		No		
Jun-17		1/06/2017	21/06/2017	6/07/2017	O&G	mg/L	Monthly	<10	1	<3		No		

Change log	Date	Change
	20/07/2020	Updated to include the testing required.