



Tahmoor Power Generation Plant

Licence Number: 11768
Licence Holder: EDL (TT) PTY LTD
Licensee Address: Remembrance Driveway TAHMOOR NSW 2573
Testing Month/Year: 2019/20
Testing Required: Level of oil and grease in oil (O&G) water separator

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	No. of times measured during month	Min. value	Mean value	Max. Value	Exceedance (Yes/No)
Jul-19	Point 08 - Effluent quality monitoring - outlet of oil water separator	3/07/19	23/07/19	25/07/19	O&G	mg/L	Monthly	<10	1	<3			No
Aug-19		16/08/19	22/08/19	28/08/19	O&G	mg/L	Monthly	<10	1	<3			No
Sep-19		2/09/19	3/10/19	11/10/19	O&G	mg/L	Monthly	<10	1	<3			No
Oct-19		24/09/19	29/10/19	7/11/19	O&G	mg/L	Monthly	<10	1	<3			No
Nov-19		4/11/19	2/12/19	13/12/19	O&G	mg/L	Monthly	<10	1	<3			No
Dec-19		18/12/219	23/12/19	7/01/20	O&G	mg/L	Monthly	<10	1	<3			No
Jan-20		6/01/20	21/01/20	5/02/20	O&G	mg/L	Monthly	<10	1	<3			No
Feb-20		2/02/20	25/03/20	25/03/20	O&G	mg/L	Monthly	<10	1	<3			No
Mar-20		3/03/20	25/03/20	25/03/20	O&G	mg/L	Monthly	<10	1	<3			No
Apr-20		8/04/20	22/04/20	7/05/20	O&G	mg/L	Monthly	<10	1	<3			No
May-20		6/05/20	21/05/20	11/06/20	O&G	mg/L	Monthly	<10	1	<3			No
Jun-20		2/06/20	18/06/20	18/06/20	O&G	mg/L	Monthly	<10	1	<3			No

Change log	Date	Change
	20/07/2020	Updated to include the testing required.