

Teralba Power Generation Plant

Licence Number: 12088 (surrendered)

Licence Holder: Envirogen PTY LTD

Licencee Address: 1 Railway Street TERALBA NSW 2284

Testing Month/Year: FY2014/15

Testing Frequency:

| Month  | Location of monitoring point                                       | Sampled  | Obtained | Published | Pollutant | Units of measure | Monitoring frequency | Licence Limit | No. measurements | Results    |
|--------|--|----------|----------|-----------|-----------|------------------|----------------------|---------------|------------------|------------|
| Jul-14 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 1/08/14  | 27/08/14 | 28/07/14  | O&G       | mg/L             | Monthly              | No visible    | 1                | no visible |
|        |  | 1/08/14  | 27/08/14 | 28/07/14  | TSS       | mg/L             | Monthly              | <50           | 1                | 11         |
|        |  | 1/08/14  | 27/08/14 | 28/07/14  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.8        |
| Aug-14 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 18/08/14 | 9/10/14  | 9/10/14   | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 18/08/14 | 9/10/14  | 9/10/14   | TSS       | mg/L             | Monthly              | <50           | 1                | 4          |
|        |  | 18/08/14 | 9/10/14  | 9/10/14   | pH        |                  | Monthly              | 6.5-8.5       | 1                | 7.2        |
| Sep-14 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 30/09/14 | 9/10/14  | 9/10/14   | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 30/09/14 | 9/10/14  | 9/10/14   | TSS       | mg/L             | Monthly              | <50           | 1                | 4          |
|        |  | 30/09/14 | 9/10/14  | 9/10/14   | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.8        |
| Oct-14 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 7/10/14  | 10/10/14 | 22/11/14  | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 7/10/14  | 10/10/14 | 22/11/14  | TSS       | mg/L             | Monthly              | <50           | 1                | 7          |
|        |  | 7/10/14  | 10/10/14 | 22/11/14  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.3        |
| Nov-14 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 21/11/14 | 16/12/14 | 16/12/14  | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 21/11/14 | 16/12/14 | 16/12/14  | TSS       | mg/L             | Monthly              | <50           | 1                | 5          |
|        |  | 21/11/14 | 16/12/14 | 16/12/14  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.6        |
| Dec-14 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 19/12/14 | 16/01/15 |           | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 19/12/14 | 16/01/15 |           | TSS       | mg/L             | Monthly              | <50           | 1                | 10         |
|        |  | 19/12/14 | 16/01/15 |           | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.78       |
| Jan-15 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 30/01/15 | 3/03/15  | 5/03/15   | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 30/01/15 | 3/03/15  | 5/03/15   | TSS       | mg/L             | Monthly              | <50           | 1                | 14         |
|        |  | 30/01/15 | 3/03/15  | 5/03/15   | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.3        |
| Feb-15 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 27/02/15 | 18/03/15 | 31/03/15  | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 27/02/15 | 18/03/15 | 31/03/15  | TSS       | mg/L             | Monthly              | <50           | 1                | 2          |
|        |  | 27/02/15 | 18/03/15 | 31/03/15  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 5.96       |
| Mar-15 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 24/03/15 | 8/04/15  | 13/04/15  | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 24/03/15 | 8/04/15  | 13/04/15  | TSS       | mg/L             | Monthly              | <50           | 1                | 4          |
|        |  | 24/03/15 | 8/04/15  | 13/04/15  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.96       |
| Apr-15 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 29/04/15 | 14/05/15 | 18/05/15  | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 29/04/15 | 14/05/15 | 18/05/15  | TSS       | mg/L             | Monthly              | <50           | 1                | 2          |
|        |  | 29/04/15 | 14/05/15 | 18/05/15  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.64       |
| May-15 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 27/05/15 | 10/07/15 | 15/07/15  | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 27/05/15 | 10/07/15 | 15/07/15  | TSS       | mg/L             | Monthly              | <50           | 1                | 1          |
|        |  | 27/05/15 | 10/07/15 | 15/07/15  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 6.48       |
| Jun-15 | Point 09 - Water quality monitoring. Outlet of oil-water separator | 29/06/15 | 10/07/15 | 15/07/15  | O&G       | mg/L             | Monthly              | No visible    | 1                | <5         |
|        |  | 29/06/15 | 10/07/15 | 15/07/15  | TSS       | mg/L             | Monthly              | <50           | 1                | 3          |
|        |  | 29/06/15 | 10/07/15 | 15/07/15  | pH        |                  | Monthly              | 6.5-8.5       | 1                | 7.11       |