

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2020/21

Testing Required: Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-20	Point 08 - Effluent quality monitoring - outlet of oil water separator	7/07/20	22/07/20	10/08/20	O&G	mg/L	Monthly	< 10	< 3	No
Aug-20		5/08/20	1/09/20	2/09/20	O&G	mg/L	Monthly	< 10	< 3	No
Sep-20		2/09/20	21/09/20	28/09/20	O&G	mg/L	Monthly	< 10	<3	No
Oct-20		8/10/20	6/11/20	12/11/20	O&G	mg/L	Monthly	< 10	<3	No
Nov-20		3/11/20	16/11/20	24/11/20	O&G	mg/L	Monthly	< 10	<3	No
Dec-20		10/12/20	22/12/20	4/01/21	O&G	mg/L	Monthly	< 10	<3	No
Jan-21					O&G	mg/L	Monthly	< 10		
Feb-21					O&G	mg/L	Monthly	< 10		
Mar-21					O&G	mg/L	Monthly	< 10		
Apr-21					O&G	mg/L	Monthly	< 10		
May-21					O&G	mg/L	Monthly	< 10		
Jun-21					O&G	mg/L	Monthly	< 10		