

**Tahmoor Power Generation Plant**

**Licence Number:** 11768

**Licence Holder:** EDL (TT) PTY LTD

**Licensee Address:** Remembrance Driveway TAHMOOR NSW 2573

**Testing Month/Year:** 2020/21

**Testing Required:** Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-20	Point 08 - Effluent quality monitoring - outlet of oil water separator	7/07/20	22/07/20	10/08/20	O&G	mg/L	Monthly	< 10	< 3	No
Aug-20		5/08/20	1/09/20	2/09/20	O&G	mg/L	Monthly	< 10	< 3	No
Sep-20		2/09/20	21/09/20	28/09/20	O&G	mg/L	Monthly	< 10	<3	No
Oct-20		8/10/20	6/11/20	12/11/20	O&G	mg/L	Monthly	< 10	<3	No
Nov-20		3/11/20	16/11/20	24/11/20	O&G	mg/L	Monthly	< 10	<3	No
Dec-20		10/12/20	22/12/20	4/01/21	O&G	mg/L	Monthly	< 10	<3	No
Jan-21		15/01/21	2/02/21	4/02/21	O&G	mg/L	Monthly	< 10	<3	No
Feb-21		3/02/21	17/02/21	22/02/21	O&G	mg/L	Monthly	< 10	<3	No
Mar-21		3/03/21	19/03/21	24/03/21	O&G	mg/L	Monthly	< 10	<3	No
Apr-21					O&G	mg/L	Monthly	< 10		
May-21					O&G	mg/L	Monthly	< 10		
Jun-21					O&G	mg/L	Monthly	< 10		