

**Tahmoor Power Generation Plant**

**Licence Number:** 11768

**Licence Holder:** EDL (TT) PTY LTD

**Licensee Address:** Remembrance Driveway TAHMOOR NSW 2573

**Testing Month/Year:** 2020/21

**Testing Required:** Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-21	Point 08 - Effluent quality monitoring - outlet of oil water separator	12/07/21	23/07/21	27/07/21	O&G	mg/L	Monthly	< 10	< 3	No
Aug-21		4/08/21	19/08/21	25/08/21	O&G	mg/L	Monthly	< 10	< 3	No
Sep-21					O&G	mg/L	Monthly	< 10		
Oct-21					O&G	mg/L	Monthly	< 10		
Nov-21					O&G	mg/L	Monthly	< 10		
Dec-21					O&G	mg/L	Monthly	< 10		
Jan-22					O&G	mg/L	Monthly	< 10		
Feb-22					O&G	mg/L	Monthly	< 10		
Mar-22					O&G	mg/L	Monthly	< 10		
Apr-22					O&G	mg/L	Monthly	< 10		
May-22					O&G	mg/L	Monthly	< 10		
Jun-22					O&G	mg/L	Monthly	< 10		