

Tahmoor Power Generation Plant

Licence Number: 11768
Licence Holder: EDL (TT) PTY LTD
Licensee Address: Remembrance Driveway TAHMOOR NSW 2573
Testing Month/Year: Financial Year 2021 - 2022
Testing Frequency: Annual for selected engines



Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Point 1 - Discharge to Air, Exhaust stack from gas engine 1	9/11/21	30/11/21	30/11/21	Nitrogen Oxides	mg/Nm3	Point 1-4 tested in odd year Point 5, 10 and 11 tested in even year	<450 Dry 273K 101.3kPa 7% O2 1 hour average	320	No
Point 2 - Discharge to Air, Exhaust stack from gas engine 2	9/11/21	30/11/21	30/11/21	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	350	No
Point 3 - Discharge to Air, Exhaust stack from gas engine 3	9/11/21	30/11/21	30/11/21	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	290	No
Point 4 - Discharge to Air, Exhaust stack from gas engine 4	9/11/21	30/11/21	30/11/21	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	340	No
Point 5 - Discharge to Air, Exhaust stack from gas engine 5	NA	NA	NA	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	NA	No
Point 10 - Discharge to Air, Exhaust stack from gas engine 6	NA	NA	NA	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	NA	No
Point 11 - Discharge to Air, Exhaust stack from gas engine 7	NA	NA	NA	Nitrogen Oxides	mg/Nm3		<450 Dry 273K 101.3kPa 7% O2 1 hour average	NA	No