

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2020/21

Testing Required: Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-21	Point 08 - Effluent quality monitoring - outlet of oil water separator	12/07/21	23/07/21	27/07/21	O&G	mg/L	Monthly	< 10	< 3	No
Aug-21		4/08/21	19/08/21	25/08/21	O&G	mg/L	Monthly	< 10	< 3	No
Sep-21		3/09/21	22/09/21	25/09/21	O&G	mg/L	Monthly	< 10	< 3	No
Oct-21		8/10/21	25/10/21	1/11/21	O&G	mg/L	Monthly	< 10	< 3	No
Nov-21		3/11/21	17/11/21	18/11/21	O&G	mg/L	Monthly	< 10	< 3	No
Dec-21		3/12/21	3/01/22	7/01/22	O&G	mg/L	Monthly	< 10	< 3	No
Jan-22		17/01/22	28/01/22	31/01/22	O&G	mg/L	Monthly	< 10	<3	No
Feb-22		1/02/22	4/03/22	10/03/22	O&G	mg/L	Monthly	< 10	<3	No
Mar-22		1/03/22	29/03/22	31/03/22	O&G	mg/L	Monthly	< 10	<3	No
Apr-22		7/04/22	5/05/22	10/05/22	O&G	mg/L	Monthly	< 10	<3	No
May-22		3/05/22	20/05/22	23/05/22	O&G	mg/L	Monthly	< 10	<3	No
Jun-22		10/06/22	27/06/22	6/07/22	O&G	mg/L	Monthly	< 10	<3	No