

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: 2020/21

Testing Required: Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-22	Point 08 - Effluent quality monitoring - outlet of oil water separator	8-07-22	26-07-22	1-08-22	O&G	mg/L	Monthly	< 10	< 3	No
Aug-22		5-08-22	22-08-22	30-08-22	O&G	mg/L	Monthly	< 10	< 3	No
Sep-22		6-09-22	21-09-22	29-09-22	O&G	mg/L	Monthly	< 10	< 3	No
Oct-22		11-10-22	24-10-22	7-11-22	O&G	mg/L	Monthly	< 10	<3	No
Nov-22					O&G	mg/L	Monthly	< 10		No
Dec-22					O&G	mg/L	Monthly	< 10		No
Jan-23					O&G	mg/L	Monthly	< 10		No
Feb-23					O&G	mg/L	Monthly	< 10		No
Mar-23					O&G	mg/L	Monthly	< 10		No
Apr-23					O&G	mg/L	Monthly	< 10		No
May-23					O&G	mg/L	Monthly	< 10		No
Jun-23					O&G	mg/L	Monthly	< 10		No