

**Tahmoor Power Generation Plant****Licence Number:** 11768**Licence Holder:** EDL (TT) PTY LTD**Licensee Address:** Remembrance Driveway TAHMOOR NSW 2573**Testing Month/Year:** FY 2022/23**Testing Required:** Level of oil and grease (O&G) in oil water separator

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-22	Point 08 - Effluent quality monitoring - outlet of oil water separator	8/07/22	26/07/22	1/08/22	O&G	mg/L	Monthly	< 10	< 3	No
Aug-22		5/08/22	22/08/22	30/08/22	O&G	mg/L	Monthly	< 10	< 3	No
Sep-22		6/09/22	21/09/22	29/09/22	O&G	mg/L	Monthly	< 10	< 3	No
Oct-22		11/10/22	24/10/22	7/11/22	O&G	mg/L	Monthly	< 10	<3	No
Nov-22		11/11/22	7/12/22	14/12/22	O&G	mg/L	Monthly	< 10	<3	No
Dec-22		2/12/22	16/12/22	22/12/22	O&G	mg/L	Monthly	< 10	<3	No
Jan-23		12/01/23	24/01/23	24/01/23	O&G	mg/L	Monthly	< 10	<3	No
Feb-23		9/02/23	27/02/23	6/03/23	O&G	mg/L	Monthly	< 10	<3	No
Mar-23		6/03/23	29/03/23	29/03/23	O&G	mg/L	Monthly	< 10	<3	No
Apr-23		6/04/23	20/04/23	24/04/23	O&G	mg/L	Monthly	< 10	<3	No
May-23		4/05/23	22/05/23	24/05/23	O&G	mg/L	Monthly	< 10	<3	No
Jun-23		6/06/23	21/06/23	23/06/23	O&G	mg/L	Monthly	< 10	<3	No