

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: FY 2023/24

Testing Required: Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-23	Point 08 - Effluent quality monitoring - outlet of oil water separator	5/07/23	23/07/23	24/07/23	O&G	mg/L	Monthly	< 10	<3	No
Aug-23		4/08/23	21/08/23	21/08/23	O&G	mg/L	Monthly	< 10	<3	No
Sep-23		7/09/23	26/09/23	26/09/23	O&G	mg/L	Monthly	< 10	<3	No
Oct-23					O&G	mg/L	Monthly	< 10		
Nov-23					O&G	mg/L	Monthly	< 10		
Dec-23					O&G	mg/L	Monthly	< 10		
Jan-24					O&G	mg/L	Monthly	< 10		
Feb-24					O&G	mg/L	Monthly	< 10		
Mar-24					O&G	mg/L	Monthly	< 10		
Apr-24					O&G	mg/L	Monthly	< 10		
May-24					O&G	mg/L	Monthly	< 10		
Jun-24					O&G	mg/L	Monthly	< 10		