

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: FY 2023/24

Testing Required: Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-23	Point 08 - Effluent quality monitoring - outlet of oil water separator	5/07/23	23/07/23	24/07/23	O&G	mg/L	Monthly	< 10	<3	No
Aug-23		4/08/23	21/08/23	21/08/23	O&G	mg/L	Monthly	< 10	<3	No
Sep-23		7/09/23	26/09/23	26/09/23	O&G	mg/L	Monthly	< 10	<3	No
Oct-23		4/10/23	20/10/23	1/11/23	O&G	mg/L	Monthly	< 10	<3	No
Nov-23		17/11/23	21/11/23	22/11/23	O&G	mg/L	Monthly	< 10	<3	No
Dec-23		4/12/23	22/12/23	8/01/24	O&G	mg/L	Monthly	< 10	<3	No
Jan-24		12/01/24	29/01/24	29/01/24	O&G	mg/L	Monthly	< 10	<3	No
Feb-24		7/02/24	20/02/24	20/02/24	O&G	mg/L	Monthly	< 10	<3	No
Mar-24		8/03/24	21/03/24	21/03/24	O&G	mg/L	Monthly	< 10	<3	No
Apr-24		2/04/24	11/04/24	12/04/24	O&G	mg/L	Monthly	< 10	<3	No
May-24		9/05/24	27/05/24	27/05/24	O&G	mg/L	Monthly	< 10	<3	No
Jun-24		6/06/24	19/06/24	19/06/24	O&G	mg/L	Monthly	< 10	<3	No