

**Tahmoor Power Generation Plant**

**Licence Number:** 11768

**Licence Holder:** EDL (TT) PTY LTD

**Licensee Address:** Remembrance Driveway TAHMOOR NSW 2573

**Testing Month/Year:** FY 2024-25

**Testing Required:** Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-24	Point 08 - Effluent quality monitoring - outlet of oil water separator	4/07/24	24/07/24	6/08/24	O&G	mg/L	Monthly	< 10	<3	No
Aug-24		8/08/24	22/08/24	22/08/24	O&G	mg/L	Monthly	< 10	<3	No
Sep-24		4/09/24	17/09/24	19/09/24	O&G	mg/L	Monthly	< 10	<3	No
Oct-24					O&G	mg/L	Monthly	< 10		
Nov-24					O&G	mg/L	Monthly	< 10		
Dec-24					O&G	mg/L	Monthly	< 10		
Jan-25					O&G	mg/L	Monthly	< 10		
Feb-25					O&G	mg/L	Monthly	< 10		
Mar-25					O&G	mg/L	Monthly	< 10		
Apr-25					O&G	mg/L	Monthly	< 10		
May-25					O&G	mg/L	Monthly	< 10		
Jun-25					O&G	mg/L	Monthly	< 10		