

Tahmoor Power Generation Plant**Licence Number:** 11768**Licence Holder:** EDL (TT) PTY LTD**Licensee Address:** Remembrance Driveway TAHMOOR NSW 2573**Testing Month/Year:** FY 2024-25**Testing Required:** Level of oil and grease (O&G) in oil water separator

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-24	Point 08 - Effluent quality monitoring - outlet of oil water separator	4/07/24	24/07/24	6/08/24	O&G	mg/L	Monthly	< 10	<3	No
Aug-24		8/08/24	22/08/24	22/08/24	O&G	mg/L	Monthly	< 10	<3	No
Sep-24		4/09/24	17/09/24	19/09/24	O&G	mg/L	Monthly	< 10	<3	No
Oct-24		24/10/24	7/11/24	7/11/24	O&G	mg/L	Monthly	< 10	<3	No
Nov-24		7/11/25	25/11/24	25/11/24	O&G	mg/L	Monthly	< 10	<3	No
Dec-24		4/12/25	6/01/25	8/01/25	O&G	mg/L	Monthly	< 10	<3	No
Jan-25		6/01/25	17/01/25	21/01/25	O&G	mg/L	Monthly	< 10	<3	No
Feb-25		7/02/25	24/02/25	24/02/25	O&G	mg/L	Monthly	< 10	<3	No
Mar-25		6/03/25	21/03/25	24/03/25	O&G	mg/L	Monthly	< 10	<3	No
Apr-25		4/04/25	17/04/25	29/04/25	O&G	mg/L	Monthly	< 10	<3	No
May-25		6/05/25	21/05/25	21/05/25	O&G	mg/L	Monthly	< 10	<3	No
Jun-25		5/06/25	1/07/25	2/07/25	O&G	mg/L	Monthly	< 10	<3	No