

Tahmoor Power Generation Plant

Licence Number: 11768

Licence Holder: EDL (TT) PTY LTD

Licensee Address: Remembrance Driveway TAHMOOR NSW 2573

Testing Month/Year: FY 2025-26

Testing Required: Level of oil and grease (O&G) in oil water separator



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-25	Point 08 - Effluent quality monitoring - outlet of oil water separator	4/07/25	21/07/25	21/07/25	O&G	mg/L	Monthly	< 10	<3	No
Aug-25		6/08/25	15/08/25	18/08/25	O&G	mg/L	Monthly	< 10	<3	No
Sep-25		4/09/25	17/09/25	7/10/25	O&G	mg/L	Monthly	< 10	<3	No
Oct-25		2/10/25	17/10/25	21/10/25	O&G	mg/L	Monthly	< 10	<3	No
Nov-25		5/11/25	24/11/25	25/11/25	O&G	mg/L	Monthly	< 10	<3	No
Dec-25		3/12/25	16/12/25	17/12/25	O&G	mg/L	Monthly	< 10	<3	No
Jan-26		12/01/26	22/01/26	22/01/26	O&G	mg/L	Monthly	< 10	<3	No
Feb-26		5/02/26	18/02/26	18/02/26	O&G	mg/L	Monthly	< 10	<3	No
Mar-26		5/03/26	24/03/26	24/03/26	O&G	mg/L	Monthly	< 10	<3	No
Apr-26		9/04/26	21/04/26	22/04/26	O&G	mg/L	Monthly	< 10	<3	No
May-26		8/05/26	18/05/26	18/05/26	O&G	mg/L	Monthly	< 10	<3	No
Jun-26					O&G	mg/L	Monthly	< 10		