

Tahmoor Power Generation Plant**Licence Number:** 11768**Licence Holder:** EDL (TT) PTY LTD**Licensee Address:** Remembrance Driveway TAHMOOR NSW 2573**Testing Month/Year:** FY 2026-27**Testing Required:** Level of oil and grease (O&G) in oil water separator

Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units of measure	Monitoring frequency required by licence	Licence Limit	Value	Exceedance (Yes/No)
Jul-26	Point 08 - Effluent quality monitoring - outlet of oil water separator	2/07/26	17/07/26	17/07/26	O&G	mg/L	Monthly	< 10	<3	No
Aug-26					O&G	mg/L	Monthly	< 10		No
Sep-26					O&G	mg/L	Monthly	< 10		No
Oct-26					O&G	mg/L	Monthly	< 10		No
Nov-26					O&G	mg/L	Monthly	< 10		No
Dec-26					O&G	mg/L	Monthly	< 10		No
Jan-27					O&G	mg/L	Monthly	< 10		No
Feb-27					O&G	mg/L	Monthly	< 10		No
Mar-27					O&G	mg/L	Monthly	< 10		No
Apr-27					O&G	mg/L	Monthly	< 10		No
May-27					O&G	mg/L	Monthly	< 10		No
Jun-27					O&G	mg/L	Monthly	< 10		No