



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units	Monitoring frequency (licence)	Measurement during month	Min	Mean	Max	Licence limit	Exceedance (Yes/No)
Jul-26	Point 13 - Air emissions monitoring		1/08/26	4/08/26	NOx	ppm	Continuous	Continuous	1819			<2878 g/min	No
	Point 11 - First Flush Effluent quality monitoring		3/08/26	4/08/26	O&G	visible	Weekly during discharge	3	Nil			nil visual	No
			3/08/26	4/08/26	pH		Weekly during discharge	3	7.60	7.8	8.1	6.5-8.5	No
	Point 12 - Process Water Effluent quality monitoring	2/07/26	17/07/26	17/07/26	O&G	visible	Monthly	1	<5			nil visual	No
		2/07/26	17/07/26	17/07/26	pH		Monthly	1	7.50			6.5-9.5	No
	Point 16 - Septic waste water Effluent quality monitoring	2/07/26	17/07/26	17/07/26	BOD	mg/L	Monthly	1	<5				
		2/07/26	17/07/26	17/07/26	FC	cfu/100mL	Monthly	1	<10				
		2/07/26	17/07/26	17/07/26	TN	mg/L	Monthly	1	32			32	
		2/07/26	17/07/26	17/07/26	TDS	mg/L	Monthly	1	392				
2/07/26		17/07/26	17/07/26	TP	mg/L	Monthly	1	2					
Aug-26	Point 13 - Air emissions monitoring				NOx	ppm	Continuous	Continuous				<2878 g/min	
	Point 11 - First Flush Effluent quality monitoring				O&G	visible	Weekly during discharge					nil visual	
					pH		Weekly during discharge					6.5-8.5	
	Point 12 - Process Water Effluent quality monitoring				O&G	visible	Monthly	1				nil visual	
					pH		Monthly	1				6.5-8.5	
	Point 16 - Septic waste water Effluent quality monitoring				BOD	mg/L	Monthly	1					
		6/08/26	10/08/26	10/08/26	FC	cfu/100mL	Monthly	1	<10				
					TN	mg/L	Monthly	1					
				TDS	mg/L	Monthly	1						
			TP	mg/L	Monthly	1							