

Appin Power Station									
Licence Number:	5482 (https://apps.epa.nsw.gov.au/prpoeoapp/)								
Licence Holder:	EDL CSM (NSW) PTY LTD								
Licensee Address:	Appin Coal Seam Methane Power Station								
Dates:	Licence Reporting Period: 3 May - 2 May Data in this report: Financial year 2026-2027								
Frequency:	Continuous monitoring for point source NOx air emissions (Point 13); Spot sampling weekly during discharge for Point 11 First Flush pH and oil and grease; Spot sampling monthly for Point 12 Process Water Effluent pH and oil and grease; Spot sampling monthly for Point 16 Septic Effluent biological oxygen demand (BOD), fecal coliforms (FC), total nitrogen (TN), TDS, total phosphorus (TP).								
Exceedances during period:	Nil								
Licence limits:	Oil & Grease: Visible while discharging pH: 6.5 - 8.5 NOx: 2878 g/min maximum on a 1 hour rolling average								
Notes and corrections:	Numbers in grey are below the limit of detection e.g. <5 mg/L								
Site	Appin								
Month Year	Date Obtained	Date Published	Sampling location	Parameter	Unit	Number of samples	Min	Mean	Max
7-2026	17/07/2026	17/07/2026	Appin EPA Point 12 Process Water	pH		1	7.5	7.5	7.5
7-2026	17/07/2026	17/07/2026	Appin EPA Point 16 Septic Quality	BOD	mg/L	1	5	5	5
7-2026	17/07/2026	17/07/2026	Appin EPA Point 16 Septic Quality	FC	cfu/100mL	1	10	10	10
7-2026	17/07/2026	17/07/2026	Appin EPA Point 16 Septic Quality	TN	mg/L	1	32	32	32
7-2026	17/07/2026	17/07/2026	Appin EPA Point 16 Septic Quality	TDS	mg/L	1	392	392	392
7-2026	17/07/2026	17/07/2026	Appin EPA Point 16 Septic Quality	TP	mg/L	1	12	12	12
7-2026	1/08/2026	4/08/2026	Appin EPA Point 11 First Flush	pH		3	7.6	7.77	8.1
7-2026	1/08/2026	4/08/2026	Appin EPA Point 11 First Flush	Oil & Grease	visual	3	0		0
7-2026	1/08/2026	4/08/2026	Appin EPA Point 13 NOx Analyser	NOx	g/min	1	1819	1819	1819
7-2026	3/08/2026	4/08/2026	Appin EPA Point 12 Process Water	Oil & Grease	visual	1	0		0
8-2026	17/08/2026	20/08/2026	Appin EPA Point 12 Process Water	pH		1	7.3	7.3	7.3
8-2026	17/08/2026	20/08/2026	Appin EPA Point 12 Process Water	Oil & Grease	visual	1	0		0
8-2026	17/08/2026	20/08/2026	Appin EPA Point 16 Septic Quality	BOD	mg/L	1	5	5	5
8-2026	17/08/2026	20/08/2026	Appin EPA Point 16 Septic Quality	FC	cfu/100mL	1	10	10	10
8-2026	17/08/2026	20/08/2026	Appin EPA Point 16 Septic Quality	TN	mg/L	1	39	39	39
8-2026	17/08/2026	20/08/2026	Appin EPA Point 16 Septic Quality	TDS	mg/L	1	403	403	403
8-2026	17/08/2026	20/08/2026	Appin EPA Point 16 Septic Quality	TP	mg/L	1	3.6	3.6	3.6

