

Tower Power Station

Licence Number: 5357

Licence Holder: EDL CSM (NSW) PTY LTD

Licencee Address: Douglas Park Drive
Douglas Park NSW 2569

Dates: Reporting Period: 3 May 2026 - 2 May 2027

Continuous monitoring for ambient NOx, O3 (taken off site) and point source NO3 air emissions;

Spot sampling weekly during discharge for First Flush pH and, oil and grease (O&G);

Frequency: Spot sampling monthly for Process Water Effluent O&G, pH;
Volume monitoring daily for waste water discharges.



Month	Location of monitoring point	Sampled	Obtained	Published	Pollutant	Units	Monitoring Frequency	Measurement during month	Min	Mean	Max	Licence Limit	Exceedance (Yes/No)
Jul-26	Point 11 - Air emissions monitoring		1/08/26	4/08/26	NOx	ppm	Continuous	Continuous		1539		< 2132 g/min	No
	Point 8 - First Flush Effluent quality monitoring		3/08/26	4/08/26	O&G	visible	Weekly during any discharge	2		Nil		nil visual	No
			3/08/26	4/08/26	pH		Weekly during any discharge	2	7.68	7.7	7.71	6.5-8.5	No
	Point 9 - Process Water Effluent quality monitoring	2/07/26	17/07/26	17/07/26	O&G	visible	Monthly			<5		nil visual	No
		2/07/26	17/07/26	17/07/26	pH		Monthly			7.4		6.5-8.5	No