

Tower Power Station									
Licence Number:	5357 (https://apps.epa.nsw.gov.au/prpoeoapp/)								
Licence Holder:	EDL CSM (NSW) PTY LTD								
Licensee Address:	Douglas Park Drive Douglas Park NSW 2569								
Dates:	Reporting Period: 3 May - 2 May Data in this report: Financial year 2026-2027								
Frequency:	Continuous monitoring for point source NOx air emissions; Spot sampling weekly during discharge for First Flush pH and oil and grease; Spot sampling monthly for Process Water Effluent pH and oil and grease.								
Exceedances during period:	Nil								
Licence limits:	Oil & Grease: Visible while discharging pH: 6.5 - 8.5 NOx: 2132 g/min maximum on a 1 hour rolling average								
Notes and corrections:									
Site	Tower								
Month Year	Obtained DateTime	Published DateTime	Sampling location	Parameter	Unit	Number of samples	Min	Mean	Max
7-2026	17/07/2026	17/07/2026	Tower EPA Point 9 Process Water	pH		1	7	7.4	7.4
7-2026	17/07/2026	17/07/2026	Tower EPA Point 9 Process Water	Oil & Grease	mg/L	1	5	5	5.0
7-2026	1/08/2026	4/08/2026	Tower EPA Point 11 NOx Analyser	NOx	Monthly max g/min	1	1539	1539.0	1539.0
7-2026	3/08/2026	4/08/2026	Tower EPA Point 8 First Flush	pH		2	7.7	7.7	7.7
7-2026	3/08/2026	4/08/2026	Tower EPA Point 8 First Flush	Oil & Grease	visual	2	0	0	0
8-2026	2026/8/2026	20/08/2026	Tower EPA Point 9 Process Water	pH		1	7.2	7.2	7.2
8-2026	2026/8/2026	20/08/2026	Tower EPA Point 9 Process Water	Oil & Grease	mg/L	1	5	5	5
8-2026	1/09/2026	1/09/2026	Tower EPA Point 11 NOx Analyser	NOx	Monthly max g/min	1	1463	1463	1463
8-2026	3/09/2026	3/09/2026	Tower EPA Point 8 First Flush	pH		5	7.5	7.6	7.8
8-2026	3/09/2026	3/09/2026	Tower EPA Point 8 First Flush	Oil & Grease	visual	5	0	0	0
9-2026	14/09/2026	16/09/2026	Tower EPA Point 9 Process Water	pH		1	7	7.2	7.2
9-2026	14/09/2026	16/09/2026	Tower EPA Point 9 Process Water	Oil & Grease	visual	1	5	5.0	5.0

